

## Milton L. Olive Middle School

Wyandanch Union Free School District

19-45375

Outlet Number	AHERA Number	Common Room Name	Outlet Type	Potable/ Non-Potable	Sample Date	Result ppb	Current Status
<b>WYAN-0450</b>	1033C2	Gym Girl's Locker Room Bathroom	Bathroom Faucet	Non-Potable	12/9/2020	<b>34</b>	Placarded for Non-Drinking Use, Pending Remediation
<b>WYAN-0213</b>	1017	Home Economics Room 20	Home Economics Faucet (Cold)	Potable	12/9/2020	<b>13</b>	Outlet Remediated and Returned to Service, Continue O&M
<b>WYAN-0195</b>	1033B1A	Gym Vestibule Boy's PE Office Bathroom	Bathroom Faucet	Non-Potable	12/9/2020	<b>4.8</b>	Outlet Remediated and Returned to Service, Continue O&M
<b>WYAN-0190</b>	1033D1A	Gym Vestibule PE Office Bathroom	Bathroom Faucet	Non-Potable	12/9/2020	<b>140</b>	Placarded for Non-Drinking Use Until Remediated
<b>WYAN-0189</b>	1040B	Room 1 Shop Bathroom	Bathroom Faucet	Non-Potable	12/9/2020	<b>31000</b>	Placarded for Non-Drinking Use Until Remediated
<b>WYAN-0176</b>	N/A	Classroom P5 Bathroom	Bathroom Faucet	Non-Potable	12/9/2020	<b>1.8</b>	Outlet Remediated and Returned to Service, Continue O&M
<b>WYAN-0154</b>	1031B2B	Cafeteria Kitchen Exit Vestibule Can Wash	Bathroom Faucet	Non-Potable	12/9/2020	<b>1.7</b>	Outlet Remediated and Returned to Service, Continue O&M